


1. THE FOLLOWING SYMBOLS SHALL DENOTE:—

ADDITIONAL MOTORISED FIRE DAMPERS
NOT INDICATED ON DRAWING TO BE
INSTALLED WHERE DUCTWORK PASSES
BETWEEN FLOORS.



1. NOTES DETAILED ON ALL DRAWINGS APPLY WHERE APPROPRIATE
- 2.
3. THE FOLLOWING SYMBOLS DENOTE

POWER SUPPLIES UNDER ELECTRICAL CONTRACT